




NOTE REGARDING WATER SERVICE LINE AND METER SIZING

The Architect shall provide provide the water meter sizing form for each of the unit models and the pool amenity to determine if the 5/8x3/4 service is adequately sized for the units. Normally a four or five bedroom unit would only require a 5/8x3/4 service, but these units are all provided with full baths in each suite and several amenity fixtures that may require higher demand and larger services.

**KDH COMMISSIONERS REVIEW PLAN
NOT RELEASED FOR CONSTRUCTION
GRAPHIC SCALE**



MICHAEL W. ROBINSON, P.E., P.L.S.
ENGINEERING AND SURVEYING
P.O. BOX 2852
KILL DEVIL HILLS, NC 27948
PHONE: 252-255-8026
EMAIL: mrobinson@obengineering.com

UTILITY PLAN



NO.	DATE	DESCRIPTION	BY
1	02-22-22	REV FOR KILL DEVIL HILLS REVIEW	MWR

OCEAN BREEZE TOWNHOMES
NORTH CAROLINA
DARE COUNTY
KILL DEVIL HILLS
902 SOUTH VIRGINIA DARE TRAIL

PROJECT: OCEAN BREEZE TOWNHOMES
DATE: 01-31-22
SCALE: 1"=20'
DESIGNED: MWR
DRAWN: MWR
SHEET: 2B OF 10
CAD FILE: ocean view cottages-kdh-base.dwg
PROJECT NO: 051121

